



AQUA TO TEST LABORATORIES
 Certified Environmental Testing

Analytical Results Summary Warren Point Elementary

Client: **Environmental Remediation & Management**
 APL Order ID: **6040462**

Contact: **Guillermo M Morales**
 Received: **4/13/16 13:37**

Sample ID/Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
6040462-01 (Drinking Water)		WP01-A		Collected: 4/13/2016 7:58				
Total Metals								
ICP-MS Lead	EPA 200.8	4/22/16 10:12	4/22/16 19:21	ND		0.00200		mg/L
6040462-02 (Drinking Water)		WP01-F		Collected: 4/13/2016 8:04				
Total Metals								
ICP-MS Lead	EPA 200.8	4/22/16 10:12	4/22/16 19:25	ND		0.00200		mg/L
6040462-03 (Drinking Water)		WP02-A		Collected: 4/13/2016 8:06				
Total Metals								
ICP-MS Lead	EPA 200.8	4/22/16 10:12	4/22/16 19:29	0.00387	3.87 ppb	0.00200		mg/L
6040462-04 (Drinking Water)		WP02-F		Collected: 4/13/2016 8:10				
Total Metals								
ICP-MS Lead	EPA 200.8	4/22/16 10:12	4/22/16 19:33	ND		0.00200		mg/L
6040462-05 (Drinking Water)		WP03-A		Collected: 4/13/2016 0:00				
Total Metals								
ICP-MS Lead	EPA 200.8	4/22/16 10:12	4/22/16 19:37	0.00568	5.68 ppb	0.00200		mg/L
6040462-06 (Drinking Water)		WP03-F		Collected: 4/13/2016 0:00				
Total Metals								
ICP-MS Lead	EPA 200.8	4/22/16 10:12	4/22/16 19:52	ND		0.00200		mg/L
6040462-07 (Drinking Water)		WP04-A		Collected: 4/13/2016 8:23				
Total Metals								
ICP-MS Lead	EPA 200.8	4/22/16 10:12	4/22/16 19:56	0.00923	9.23	0.00200		mg/L
6040462-08 (Drinking Water)		WP04-F		Collected: 4/13/2016 8:27				
Total Metals								
ICP-MS Lead	EPA 200.8	4/22/16 10:12	4/22/16 20:00	ND		0.00200		mg/L
6040462-09 (Drinking Water)		WP05-A		Collected: 4/13/2016 0:00				
Total Metals								
ICP-MS Lead	EPA 200.8	4/22/16 10:12	4/22/16 20:04	0.0129	12.9	0.00200		mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns.



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Analytical Results Summary Warren Point Elementary

Client:	Environmental Remediation & Management	Contact:	Guillermo M Morales
APL Order ID:	6040462	Received:	4/13/16 13:37

Sample ID/Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
6040462-10 (Drinking Water)		WP05-F		Collected:	4/13/2016	0:00		
Total Metals								
ICP-MS Lead	EPA 200.8	4/22/16 10:12	4/22/16 20:08	0.00526	5.26 fob	0.00200		mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns.

APL 6040462

AQUA PRO-TECH LABORATORIES



www.aquaprotechlabs.com
1275 BLOOMFIELD AVENUE • BUILDING 9
FAIRFIELD, NEW JERSEY 07004

TEL: 973.227.0422
FAX: 973.227.2813

CONTAMINATION LEVEL

HIGH MEDIUM LOW

CHAIN OF CUSTODY

CLIENT: FRM
 ADDRESS: 2010 Park A.
 PHONE: 973-940-3523
 E-MAIL: luciano@aquaprotech.com
 PROJECT NAME: Water Treatment
 PROJECT ADDR: 2010 Park A.
 PROJECT C/P: 10

SEND REPORT TO:

ADDRESS:

PHONE:

FAX:

SEND INVOICE TO:

ADDRESS:

SAMPLED BY: John Adams

TURN-AROUND TIME

- APL STANDARD 2 weeks
- RUSH APPROX 80% higher
- 24 hr. date & time required
- 48 hr. date & time required
- 72 hr. date & time required
- 1 week

REPORT FORMAT

- RESULTS ONLY
- NJ DEP REDUCED
- NJ DEP FULL
- STATE FORMS/E2 REPORTING

- ELECTRONIC FORMAT
- EMAIL DELIVERY
- WASTE EDC
- EXCEL
- SPSS

MATRIX ABBREVIATIONS: D - DRINKING WATER G - GROUNDWATER W - WASTEWATER S - SOIL SL - SLUDGE C - CONCRETE L - LAKE

APL Lab ID#	Sample Source: Field ID	Date	Time	Sample Type	No. of Samples	Pressure	Analysis Requested
01 W001-A	Water	2-16-04	7:00	D	1		
02 W001-F	Water	2-16-04	8:00	D	1		
03 W002-A	Water	2-16-04	8:00	D	1		
04 W002-F	Water	2-16-04	8:00	D	1		
05 W003-A	Water	2-16-04	8:00	D	1		
06 W003-F	Water	2-16-04	8:00	D	1		
07 W004-A	Water	2-16-04	8:00	D	1		
08 W004-F	Water	2-16-04	8:00	D	1		
09 W005-A	Water	2-16-04	8:00	D	1		

RELINQUISHED BY (Print): John Adams RECEIVED BY (Print): John Adams
 Signature: [Signature] Signature: [Signature]
 RELINQUISHED BY (Print): _____ RECEIVED BY (Print): _____
 Signature: _____ Signature: _____
 RELINQUISHED BY (Print): _____ RECEIVED BY (Print): _____
 Signature: _____ Signature: _____

COMMENTS/SPECIAL INSTRUCTIONS

Cooler Temp. upon receipt at lab: 36

